

I N T E R P R E T A T I O N

Interpretation Number: 5/2006


Code: USBC, Part I, Virginia Construction Code

Section No(s): 913

QUESTION: When in-building emergency communication equipment is required by Section 913, is the building owner required to provide cabling and pathways and all necessary infrastructure to meet the acceptance test in Section 913.3?

ANSWER: Yes.

This Official Interpretation was issued by the State Building Code Technical Review Board at its meeting of January 22, 2010.



Chairman, State Building Code Technical Review Board